



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY, PAYYANNUR
WATER ANALYSIS REPORT



TC-10908

Tele phone No : 04985290734
email : kwaqualitysdlpayyannur@gmail.com

ULR-TC109062400007384F

Report No - KWA/QA/R/03/7384/1/27/6474		Date :05/03/2024		
Customer Name and Address WADIHUDA PROGRESSIVE ENGLISH MEDIUM SCHOOL WADIHUDA , P O PAYANGADI , KANNUR DIST (Forwarded by Health Inspector P H C Muttam) (NON DOMESTIC PURPOSE)	1. Date of receipt	:04/03/2024		
	2. Sampling provided by	:(Customer(QUA_113916)		
	3. Sample Code	: 03/24 (565)		
	4. Source of Sample	:Open Well(Sealed)		
	5. Sample quantity	: 1 lit		
	6. Test performing dates	From : 04/03/2024 To : 05/03/2024		
Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1 Colour	HAZEN	IS 3025 (part 04) -2021	5	-
2 Odour		IS 3025 (part 5) -2018	Agreeable	-
3 Turbidity	(NTU)	IS 3025 (part 10) -2023	1	0.80
4 pH		IS 3025 (part 11) -2022	6.5 to 8.5	5.81
5 Total Alkalinity (as CaCO ₃)	(mg/litre)	IS 3025 (part 23) -2023	200	-
6 Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (part 16) -2023	500	-
7 Total Hardness (as CaCO ₃)	(mg/litre)	IS 3025 (part 21) -2009 (Reaffirmed 2019)	200	8.00
8 Calcium (as Ca)	(mg/litre)	IS 3025 (part 40) -1991 (Reaffirmed 2019)	75	-
9 Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46) -2023	30	-
10 Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) -1988 (Reaffirmed 2019)	250	11.69

Remarks:
The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

*BDL: Below Detection Limit

For PROGRESSIVE ENGLISH SCHOOL

Authorised By



Manager

Sujithra. R

Principal End Of Report*

KWA/QC/SDL/PNR/R/17

Progressive English School
WADIHUDA PAYANGADI
Issue No: 01

Issue Date : 01.12.2021

Dona Joy Dona
Deputy Quality Manager

DEPUTY QUALITY MANAGER
QUALITY CONTROL SUBDISTRICT LAB PAYYANNUR
KERALA WATER AUTHORITY PAYYANNUR
Rev No: 00 Rev Date:00



**KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY, PAYYANNUR
WATER ANALYSIS REPORT**

Tele phone No : 04985290734

email : kwaqualitysdlpayyannur@gmail.com

Report No - KWA/QA/R/03/7384/J/27/6474		Date :05/03/2024			
Customer Name and Address WADIHUDA PROGRESSIVE ENGLISH MEDIUM SCHOOL WADIHUDA , P O PAYANGADI , KANNUR DIST (Forwarded by Health Inspector P H C Muttam) (NON DOMESTIC PURPOSE)		1. Date of receipt	:04/03/2024		
		2. Sampling provided by	:(Customer(QUA_113916)		
		3. Sample Code	: 03/24 (565)		
		4. Source of Sample	:Open Well(Sealed)		
		5. Sample quantity	: 1 lit		
		6. Test performing dates	From : 04/03/2024	To : 05/03/2024	
Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14) -2013 (Reaffirmed 2019)		46.14
2	Acidity	(mg/litre)	IS 3025 (part 22) -1986 (Reaffirmed 2019)		-
3	Sulphate (asSO ₄)	(mg/litre)	IS 3025 (Part 24 /Sec 1):2022	200	-
4	Fluoride (as F)	(mg/litre)	APHA 24 th Edition 4500-F-D SPADNS Method.	1	-
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) -2003 (Reaffirmed 2014)	1	BDL
6	Nitrate (as NO ₃)	(mg/litre)	APHA23rd Edition (UV Screening method)	45	BDL
7	Residual Chlorine	(mg/litre)	IS 3025 (part 26)- 2021	0.2	-

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

*BDL : Below Detection Limit

For PROGRESSIVE ENGLISH SCHOOL

Sujithra. R
Principal

Authorised By

Dona Joy Don
Deputy Quality Manager

Manager

* End Of Report*

KWA/QC/SDL/PNR/R/17

Issue No: 01

Issue Date : 01.12.2021

DEPUTY QUALITY MANAGER
DEPUTY QUALITY MANAGER
DEPUTY QUALITY MANAGER
SUBDISTRICT LAB PAYYAN
KERALA WATER AUTHORITY PAYYANNUR
Page 2 of 2





**KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY, PAYYANNUR
WATER ANALYSIS REPORT**

Tele phone No : 04985290734
email : kwaqualitysdlpayyannur@gmail.com

Report No - KWA/QA/R/03/7437b/R/2/35(638)		Date :15/03/2024			
Customer Name and Address PROGRESSIVE ENGLISH SCHOOL AFFILIATION NO: 930127 WADIHUDA,PAYANGADI P O KANNUR KERALA (NON DOMESTIC PURPOSE)		1. Date of receipt		:14/03/2024	
		2. Sampling provided by		:(Customer(QUA_116336)	
		3. Sample Code		: 03/24 (637)	
		4. Source of Sample		:Open Well	
		5. Sample quantity		: 100ml	
		6. Test performing dates		From: 14/03/2024	
SI No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	CFU /100 ml	IS 15185:2016;ISO 93081:2014	Nil	280
2	E.Coli	CFU /100 ml	IS 15185:2016;ISO 93081:2014	Nil	Nil

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

For PROGRESSIVE ENGLISH SCHOOL



Sujithra. R
Principal
Progressive English School
(Senior Secondary)
WADIHUDA, PAYANGADI P O, 930127

Authorised By

* End Of Report*

KWA/QC/SDL/PNR/R/17

Issue No: 01 Issue Date : 01.12.2021

Bacteriologist

BACTERIOLOGIST
QUALITY CONTROL SUBDISTRICT LAB PAYYANNUR
Rev No: 00KERALA WATER AUTHORITY
PAYYANNUR - 670 307

NO PH/S/1/2024

PHC MUTTAM


02/04/2024

SANITARY CERTIFICATE


Inspected the Progressive English School, Wadihuda, Payangadi,
P.O.Payangadi, Kannur, Kerala, India-670303 building No-VI/325, 326, 331, 332 and
certified that the accommodation provided is sufficient and properly ventilated, lighted,
kept clean and the building is maintained substantial repaired and the bathing and the
latrine arrangements are adequate and satisfactory. Drinking water and necessary
facilities have been provided. This certificate is issued for the yearly updation of datas
for CBSE (2024-25).


For PROGRESSIVE ENGLISH SCHOOL
Manager


Sujithra. R
Principal
Progressive English School
(Senior Secondary)
WADIHUDA, PAYANGADI


HEALTH INSPECTOR
P. H. C. MUTTAM


Date...
P.O. VENGARA
670305
OFFICE OF THE PRIMARY HEALTH CENTRE
MUTTAM


MEDICAL OFFICER
PRIMARY HEALTH CENTRE
MUTTAM-670305